

January 8, 2014

Performance Annual Report

I. General Information

Facility/System Name: Town of Spring Lake Regional Wastewater Treatment Plant

Responsible Entity: Town of Spring Lake

Person in Charge/Contact: Richard Mendez (910) 497-5748

Applicable Permits: Wastewater Discharge Permit Number NC0030970 expires May 31, 2016

Land Application of Bio-Solids Permit Number WQ0001086 expires January 31, 2015

Description of Treatment Process:

The Town of Spring Lake Regional Wastewater Treatment Plant is a Dual Train, Extended Aeration Plant with Secondary Clarification for the separation of liquids and solids, Post Aeration, Chlorination and De-Chlorination. Aerobic Digestion has been supplemented with Lime Stabilization to ensure that the treated Bio-solids produced after plant processing, meet EPA and NCDWQ regulations prior to disposal by land application. A monthly report of plant performance as determined by Laboratory analysis is submitted to the NCDWQ and an annual Bio-solids application report and Laboratory analysis is submitted to the EPA and NCDWQ Non-Discharge Branch. The plant is also responsible for two lift stations in the town's collection system. No reportable discharges were experienced by the Cedar Creek or Hinkle Lift Station.

II. Performance

Text Summary of System Performance for Calendar Year 2013:

The Town of Spring Lake Wastewater Treatment processed for discharge into the Lower Little River 309,887,000 gallons of wastewater during the calendar year 2013. While producing the treated effluent the plant produced 79.04 dry tons of Bio-solids for Land Application. The plant flow ranged from a low flow on November 25th of 565,000 gallons to a high flow on June 9th of 2,254,000 gallons.

A by month accounting of the system for CY 2013 follows:

January – 23,891,000 gallons of treated effluent discharged, No permit violations noted.

February – 22,289,000 gallons of treated effluent discharged, No permit violations noted.

March – 24,230,000 gallons of treated effluent discharged, No permit violations noted.

April – 25,029,000 gallons of treated effluent discharged, No permit violations noted.

May – 24,668,000 gallons of treated effluent discharged, No permit violations noted.

June – 32,128,000 gallons of treated effluent discharged, No permit violations noted.

July – 36,346,000 gallons of treated effluent discharged, No permit violations noted.

August – 29,619,000 gallons of treated effluent discharged, No permit violations noted.

September – 24,150,000 gallons of treated effluent discharged, No permit violations noted.

October – 23,125,000 gallons of treated effluent discharged, No permit violations noted.

November – 21,308,000 gallons of treated effluent discharged, No permit violations noted.

December – 23,094,000 gallons of treated effluent discharged, No permit violations noted.

During CY 2013, the plant processed 309,887,000 gallons of wastewater and returned it to the surface waters of the state of North Carolina via its permitted discharge point into the Lower Little River.

The Collection system had a total of (0) zero reportable (SSO) Sanitary Sewer Overflows, during the CY 2013:

The Town of Spring Lake has been awarded a low interest loan to “refurbish” the plant. This process is in work and will include a new septage receiving component, a refitted grit chamber, new solids removal equipment, four new recycle pumps and the installation of liquid disinfectant equipment. The net result of the work will be a plant ready to serve the region for the next 15 to 20 years. Several inspections were completed during the past year to include a site specific storm water inspection, an inspection of the lab, and one NCDENR; no violations were noted and all minor discrepancies have been corrected.

III. Notification

A copy of this correspondence was placed on the Town of Spring Lake's web site.

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Byron Blumenfeld Date 8 January 2014

Water Resources Manager

Town of Spring Lake, NC