

ADDENDUM _____
 DRY EXTENDED DETENTION BASIN
 STORMWATER BEST MANAGEMENT PRACTICE
 MINIMUM MAINTENANCE MEASURES

Project Name: _____

I will keep a maintenance record on this BMP. This maintenance record will be kept in a log in a known set location. Any deficient BMP elements noted in the inspection will be corrected, repaired or replaced immediately. These deficiencies can affect the integrity of structures, safety of the public, and the removal efficiency of the BMP.

The dry extended detention basin system is defined as the dry detention basin, outlet structure, pretreatment including forebays and the vegetated filter if one is provided.

This system:

- Incorporates a vegetated filter at the outlet (check one) YES NO
- Incorporates pretreatment other than a forebay (check one) YES NO

Important operation and maintenance procedures:

- The drainage area will be managed to reduce the sediment load to the dry extended detention basin.
- Immediately after the dry extended detention basin is established, the vegetation will be watered twice weekly if needed until the plants become established (commonly six weeks).
- No portion of the dry extended detention pond will be fertilized after the first initial fertilization that is required to establish the vegetation.
- I will maintain the vegetation in and around the basin at a height of approximately six inches.
- Once a year, a dam safety expert will inspect the embankment.

After the dry extended detention basin is established, it will be inspected **once a quarter and within 24 hours after every storm event greater than 1.0 inches**. Records of operation and maintenance will be kept in a known set location and will be available upon request.

Inspection activities shall be performed as follows. Any problems that are found shall be repaired immediate

BMP element:	Potential problem:	How I will remediate the problem:
The entire BMP	Trash/debris is present.	Remove the trash/debris.
The inlet device: pipe or swale	The pipe is clogged (if applicable).	Unclog the pipe. Dispose of the sediment off-site.
	The pipe is cracked or otherwise damaged (if applicable).	Replace the pipe.

BMP element:	Potential problem:	How I will remediate the problem:
The inlet device: pipe or swale (continued)	Erosion is occurring in the swale (if applicable).	Regrade the swale if necessary to smooth it over and provide erosion control devices such as reinforced turf matting or riprap to avoid future problems with erosion.
The forebay	Sediment has accumulated and reduced the depth to 75% of the original design depth	Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP.
	Erosion has occurred or riprap is displaced.	Provide additional erosion protection such as reinforced turf matting or riprap if needed to prevent future erosion problems.
	Weeds are present.	Remove the weeds, preferably by hand.
The main treatment area	Sediment has accumulated and reduced the depth to 75% of the original design depth	Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP. Re-vegetate disturbed areas immediately with sod (preferred) or seed protected with securely staked erosion mat.
	Water is standing more than 5 days after a storm event.	Check outlet structure for clogging. If it is a design issue, consult an appropriate professional.
	Weeds and noxious plants are growing in the main treatment area.	Remove the plants by hand or by wiping them with herbicide (do not spray).
The embankment	Shrubs or trees have started to grow on the embankment.	Remove shrubs or trees immediately.
	Grass cover is unhealthy or eroding.	Restore the health of the grass cover – consult a professional if necessary.
	Signs of seepage on the downstream face.	Consult a professional.
	Evidence of muskrat or beaver activity is present.	Use traps to remove muskrats and consult a professional to remove beavers.
	An annual inspection by an appropriate professional show that the embankment needs repair.	Make all needed repairs.
The outlet device	Clogging has occurred.	Clean out the outlet device. Dispose of the sediment off-site.
	The outlet device is damaged	Repair or replace the outlet device.

BMP element:	Potential problem:	How I will remediate the problem:
The receiving water	Erosion or other signs of damage have occurred at the outlet.	Contact the NC Division of Water Quality Raleigh Regional Office, or the 401 Oversight Unit at 919-807-6300.
The perimeter of the dry extended detention basin	Areas of bare soil and/or erosive gullies have formed.	Regrade the soil if necessary to remove the gully, and then plant a ground cover and water until it is established. Provide lime and a one-time fertilizer application.

I, _____, hereby acknowledge that I am the financially responsible party for maintenance of this stormwater BMP. I will perform the maintenance as outlined above, in compliance with the requirements of the Town of Spring Lake’s Phase II Stormwater Ordinance.

Signature: _____ Date: _____

STATE OF NORTH CAROLINA
COUNTY OF _____

I, _____, a Notary Public of _____ County, in the State of North Carolina, do hereby certify that _____ personally appeared before me this day and acknowledged the execution of the foregoing instrument.

Witness my hand and seal, this _____ day of _____, 20_____.

(SEAL)

Notary Public

My Commission Expires: _____