

ADDENDUM _____
 STORMWATER WETLAND
 STORMWATER BEST MANAGEMENT PRACTICE
 MINIMUM MAINTENANCE MEASURES

Project Name: _____

I will keep a maintenance record on this BMP. This maintenance record will be kept in a log in a known set location. Any deficient BMP elements noted in the inspection will be corrected, repaired or replaced immediately. These deficiencies can affect the integrity of structures, safety of the public, and the removal efficiency of the BMP.

Important operation and maintenance procedures:

- Immediately following construction of the stormwater wetland, bi-weekly inspections will be conducted and wetland plants will be watered bi-weekly until vegetation becomes established (commonly six weeks).
- No portion of the stormwater wetland will be fertilized after the first initial fertilization that is required to establish the wetland plants.
- Stable groundcover will be maintained in the drainage area to reduce the sediment load to the wetland.
- Once a year, a dam safety expert should inspect the embankment.

After the stormwater wetland is established, I will inspect it **monthly and within 24 hours after every storm event greater than 1.0 inches**. Records of operation and maintenance will be kept in a known set location and will be available upon request.

Inspection activities shall be performed as follows. Any problems that are found shall be repaired immediately.

BMP element:	Potential problem:	How I will remediate the problem:
Entire BMP	Trash/debris is present.	Remove the trash/debris.
Perimeter of wetland	Areas of bare soil and/or erosive gullies have formed.	Regrade the soil if necessary to remove the gully, and then plant a ground cover and water until it is established. Provide lime and a one-time fertilizer application.
	Vegetation is too short or too long.	Maintain vegetation at an appropriate height.
Inlet device: pipe or swale	The pipe is clogged (if applicable).	Unclog the pipe. Dispose of the sediment offsite.
	The pipe is cracked or otherwise damaged (if applicable).	Replace the pipe.

BMP element:	Potential problem:	How I will remediate the problem:
Inlet device: pipe or swale (continued)	Erosion is occurring in the swale (if applicable).	Regrade the swale if necessary to smooth it over and provide erosion control devices such as reinforced turf matting or riprap to avoid future problems with erosion.
Forebay	Sediment has accumulated in the forebay to a depth that inhibits the forebay from functioning well.	Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP.
	Erosion has occurred.	Provide additional erosion protection such as reinforced turf matting or riprap if needed to prevent future erosion problems.
	Weeds are present.	Remove the weeds, preferably by hand. If a herbicide is used, wipe it on the plants rather than spraying.
Deep pool, shallow water and shallow land areas	Algal growth covers over 50% of the deep pool and shallow water areas.	Consult a professional to remove and control the algal growth.
	Cattails, phragmites or other invasive plants cover 50% of the deep pool and shallow water areas.	Remove invasives by physical removal or by wiping them with herbicide (do not spray) – consult a professional.
	Shallow land remains flooded more than 5 days after a storm event.	Unclog the outlet device immediately.
	Plants are dead, diseased or dying.	Determine the source of the problem: soils, hydrology, disease, etc. Remedy the problem and replace plants. Provide a one-time fertilizer application to establish the ground cover if necessary.
	Best professional practices show that pruning is needed to maintain optimal plant health.	Prune according to best professional practices.
	Sediment has accumulated and reduced the depth to 75% of the original design depth of the deep pools.	Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP.
Embankment	A tree has started to grow on the embankment.	Consult a dam safety specialist to remove the tree.

BMP element:	Potential problem:	How I will remediate the problem:
Embankment (continued)	An annual inspection by appropriate professional shows that the embankment needs repair.	Make all needed repairs.
	Evidence of muskrat or beaver activity is present.	Consult a professional to remove muskrats or beavers.
Micropool	Sediment has accumulated and reduced the depth to 75% of the original design depth.	Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP.
Outlet device	Clogging has occurred.	Clean out the outlet device. Dispose of the sediment off-site.
	The outlet device is damaged	Repair or replace the outlet device.
Receiving water	Erosion or other signs of damage have occurred at the outlet.	Contact the NC Division of Water Quality Raleigh Regional Office, or the 401 Oversight Unit at 919-807-6300.

I, _____, hereby acknowledge that I am the financially responsible party for maintenance of this stormwater BMP. I will perform the maintenance as outlined above, in compliance with the requirements of the Town of Spring Lake's Phase II Stormwater Ordinance.

Signature: _____ Date: _____

STATE OF NORTH CAROLINA
COUNTY OF _____

I, _____, a Notary Public of _____ County, in the State of North Carolina, do hereby certify that _____ personally appeared before me this day and acknowledged the execution of the foregoing instrument.

Witness my hand and seal, this _____ day of _____, 20_____.

(SEAL)

Notary Public

My Commission Expires: _____